



PSAM 14, 16-21 September 2018, Los Angeles, CA

---

## **Insights from Internal Fire PSA of UK ABWR in Generic Design Phase**

September 17, 2018  
Internal Hazards PSA/PRA I

Yuki Ishiwatari (Hitachi-GE Nuclear Energy, Ltd.)  
Daichi Shiota (Hitachi-GE Nuclear Energy, Ltd.)  
Paul Guymer (Jacobsen Analytics Ltd.)

# 1. Introduction – UK ABWR

- Hitachi-GE proposed to build Advanced Boiling Water Reactor (ABWR) plants in UK, based on enhanced Japanese ABWR design.
- Hitachi-GE has been honored to receive a Design Acceptance Confirmation (DAC) from ONR, and Statement of Design Acceptability (SoDA) from Environment Agency and Natural Resources Wales on 13 Dec. 2017.
- The generic Pre-Construction Safety Report (PCSR) is the main submission for Generic Design Assessment (GDA) supplied by Hitachi-GE. UK ABWR PSA is provided in the chapter 25 of PCSR.

More information found at:

*Hitachi-GE Nuclear Energy, Ltd., Generic PCSR Chapter 25: Probabilistic Safety Assessment,*

<http://www.hitachihgne-uk-abwr.co.uk/downloads/2017-12-14/UKABWRGA91-9101-0101-25000-RevC-PB.pdf>

# 1. Introduction – UK ABWR PSA for GDA

HITACHI



Source of Radioactivity	Internal events	Internal fire*	Internal flood*	Seismic events*	Other IHs*	Other EHs*		
Reactor (at Power)	<b><u>Detailed PSA</u></b>				Bounding assessment			
Reactor (Shutdown)			Scoping Analysis					
SFP				<b><u>Detailed PSA</u></b>				
Fuel Route	<div style="border: 1px solid orange; padding: 5px; display: inline-block; margin-bottom: 10px;"> <b>Covered by this presentation.</b> </div> Qualitative discussions to argue risk is insignificant							
Turbine system							Simplified assessment	
Radwaste system								

\* Retained after screening process in IAEA SSG-3

More information found in:

*N. Hirokawa, et al., OVERVIEW OF PSA FOR THE UK ABWR GENERIC DESIGN ASSESSMENT, ICONE26-82553*

# 1. Introduction – Background and Objective

HITACHI



NUREG/CR-6850 and NUREG/CR-7114 are generally intended for application to an operating plant rather than a plant in design phase.

## **Certain challenges: Absence of**

- Detailed circuit design
- Detailed locations of raceways and ignition sources
- Comprehensive Fire Hazard Analysis (FHA)
- Operating procedures

→ Simplified and conservative approaches developed\*

## **Objective of this presentation:**

- Further describes approaches to generic design FPSA (Section 2)
- Introduces approaches to model refinements (Section 3)
- Introduces results and insights (Section 5)
- Introduces peer reviews (Section 6)
- Introduces risk-informed activities (Sections 4 and 7)

\*P. Guymer, et al., "DEVELOPMENT OF INTERNAL FIRE PSA FOR NEW BUILD UK GENERIC DESIGN ASSESSMENT", 15th Int. Post-Conf. Seminar on FIRE SAFETY IN NUCLEAR POWER PLANTS AND INSTALLATIONS, Bruges, Belgium, October, 2017.

## 2. Approaches to Generic Design FPSA


HITACHI



Guidance / Standard	Contents Used
NUREG/CR-6850	Overall Guidance
NRC/NEI Frequently Asked Questions	Supplements to NUREG/CR-6850
NUREG/CR- 7114	Additional Guidance for Shutdown FPSA
NUREG-2169	Generic Ignition Frequencies, Generic Non-suppression Probabilities
NUREG/CR-7150	Spurious Operation Probabilities, Failure Probabilities to Clear Spurious Operation
NUREG-1921	Internal Fire HRA Guidance
NUREG-1855 / EPRI-1026511	Approach to Uncertainties
NEI 00-01	Multiple Spurious Operations Identification
NEI 07-12	Peer Review Process
ASME/ANS RA-Sb-2013	Requirements (for Peer Review)
Technical Assessment Guides (TAGs)	UK Regulatory Expectations
AESJ-SC-RK007:2014	Additional Guidance

## 2. Approaches to Generic Design FPSA

HITACHI




NUREG/CR-6850 Vol.1, Figure 1

## 2. Approaches to Generic Design FPSA

HITACHI



- Conservative assumptions upon lack of special information.
- Staged MCA approach.
- MCR abandonment analysis.
- Monte Carlo cabinet fire growth utilizing NUREG/CR-6850 Appendix L and S



### 3. Approaches to Reduce Conservatism

HITACHI



#### **Task 5 - Refinement of Plant Response Model**

- Updated success criteria and event trees.
- Credited additional functions and interlocks.
- Credited more instrumentations supporting operator actions.

#### **Task 5/ Task 10 - Spurious Operation Duration Analysis**

- Applied to SOVs for SRVs and MSIV etc.
- Determined key timings of clearing spurious operation from supporting thermal-hydraulic analyses
- Introduced conditional failure probabilities to clear spurious operations, based on NUREG/CR-7150 Volume 2.



### 3. Approaches to Reduce Conservatism

HITACHI




#### **Task 11 – Iterative Refinements of Detailed Fire Modelling**

- Screened specific ignition sources for a POS if justified to be de-energized by interlocks and/or strict administrative control.
- Shifted center of ZOI if secondary combustible dominated HRR.
- Refined selection of critical cables vs. non-critical cables.
- Refined treatment of non-rated boundaries
- Used realistic flame propagation rate (Section R.4.1.2 of NUREG/CR-6850) for cables meeting appropriate standards.
- Applied CFAST modelling for risk significant MCA scenarios to consider oxygen depletion, in addition to FDTs (NUREG-1805).

#### **Task 12 – Refined FPSA specific HEP multiplier**

- For risk significant HEPs
- Justified by Tabular Task Analysis and Human Error Analysis

# 4. Risk-informed Improvements during FPSA Development



More information found in:

Y. Ishiwatari, et al., "Risk-Informed Design for UK ABWR Project", *Int. Conf. on Topical Issues in Nuclear Installation Safety, IAEA CN-251, Vienna, Austria, June 2017.*

## 5. Results and Insights - Reactor at Power HITACHI



Same order of CDF as the internal events by model refinements as much as practically feasible given generic design progress and project schedule, as well as risk informed improvements

	CDF (/y)	Contribution to Fire at Power CDF	LRF (/y)	Contribution to Fire at Power LRF
Task 11a Detailed Fire Models	2.09E-07	42.2 %	1.78E-07	67.2 %
Task 11b Main Control Room	7.82E-09	1.6 %	1.95E-09	0.7 %
Task 7 Whole Room Damage	8.24E-08	16.6 %	3.42E-08	12.9 %
ALL Single Compartment	2.99E-07	60.4 %	2.14E-07	80.8 %
Task 11c MCA Type 1*	5.38E-09	1.1 %	3.97E-09	1.5 %
Task 11c MCA Type 2*	2.12E-08	4.3 %	6.13E-09	2.3 %
Task 11c MCA Type 3*	7.15E-08	14.4 %	1.18E-08	4.4 %
Task 11c MCA Type 4*	9.82E-08	19.8 %	2.90E-08	10.9 %
ALL Multi Compartment	1.96E-07	39.6 %	5.08E-08	19.2 %
At Power Fire Total	4.95E-07	-	2.65E-07	-
<i>Internal Events at Power (for comparison)</i>	2.27E-07	-	5.20E-08	-

\*Type 1: Impacting temperature sensitive equipment in exposed PAUs by HGL.

\*Type 2: Not producing a damaging HGL in the exposing PAU but potentially impacting the opposite side of a non-rated barrier by plume or radiant heat.

\*Type 3: Producing a damaging HGL in the exposing compartment, and potentially impacting a fire zone surrounded by fire barriers.

\*Type 4: Associated Type 3 scenario with further impact on adjacent fire zone with evaluated Barrier Failure Probability.

## 5. Results and Insights - Reactor at Power

HITACHI



- **Reactor Building electrical rooms** as the highest contributors, in large part due to existence of a large number of ignition sources (cabinets) and critical cables.
- Backup Building (B/B), Control Building (C/B) and Turbine Building (T/B) as relatively low contributors, which implied the effectiveness of fire rated boundaries additionally introduced for defense-in-depth and per **risk-informed recommendations**.
- **Low contribution from MCR** fire scenarios due to:
  - ✓ Class 1 digital C&I controller separated from the MCR fire zone
  - ✓ Two remote shutdown rooms and a B/B control panel room
- Accident Class AE (Large LOCA with loss of injection) as the highest contributor to CDF due to the high contribution from the MSO scenarios involving **spurious operations of more than 7 SRVs**.
- Relatively high LRF to CDF ratio ( $> 50\%$ ), mainly due to the contribution from the Accident Classes involving containment failure / bypass.



# Containment failure / bypass Level 1 end sta




Figure 2: Contribution of Accident Class to CDF

# 5. Results and Insights - Scoping Analyses of Shutdown POSs



Conservative scoping analysis of representative POSs (selected from plant conditions and internal events PSA insights) showed insignificant fire risk compared to at Power.

**POS C: Transition to closed condition of Containment/RPV heads with Divisions 1 and 3 in maintenance**

**POS B-2: Full water level in reactor well and gate open with Divisions 1 and 3 in maintenance**

	FDF (/y) of POS C	Contribution to FDF of POS C	FDF (/y) of POS B-2	Contribution to FDF of POS B-2
ALL Single Compartment	1.68E-08	38.2 %	6.58E-09	33.8 %
ALL Multi Compartment	2.72E-08	61.8 %	1.29E-08	66.2 %
Fire Total for each POS	4.40E-08	-	1.95E-08	-
Internal Events Shutdown (for Comparison)	5.38E-08	-	1.46E-08	-

## Insights:

- Small contribution of fires in **containment**.
- Need attention to **fire-induced spurious overflow** of reactor well and SFP and subsequent internal flooding.
- Larger contribution of T/B fires than at Power due to higher transient fire frequencies during shutdown per NUREG-2169.

## 5. Results and Insights - Scoping Analyses of SFP at Power

Conservative scoping analysis of SFP and sensitivity analyses showed insignificant fire risk compared to reactor at Power.

	FDF (/y) at Power	Contribution to Fire FDF of SFP at Power
ALL Single Compartment	1.95E-07	32.7 %
ALL Multi Compartment	4.03E-07	67.3 %
Fire Total for SFP at Power POS	5.98E-07	-
Internal Events SFP PSA (for comparison)	3.17E-08	-

Further reduction expected per sensitivity analyses, application of refinements performed for at Power FPSA, and the nature of SFP faults (e.g., large time margin to fuel damage).

### Sensitivity Analyses:

- Consider realistic time available for terminating fire-induced flooding – 15% reduction
- Consider realistic consequence from containment failure without core damage (Level 1 PSA success sequences) – 20% reduction
- Remove FDF which is double-counting the LRF of reactor – 30% reduction

## 6. Peer Reviews

- Independent Peer Review team organized by US industry experts
- NEI 07-12 process
- Multiple in-process reviews and follow-on reviews
- Part 4 of ASME/ANS RA-Sb-2013
- UK Technical Assessment Guides (TAGs) for PSA/HRA
- Met large part of requirements for Capability Category II or III of ASME/ANS RA-Sb-2013

More information found at

*D. Henneke, et al., The Use of Comprehensive In-Process Peer Reviews in Support of the UK ABWR PSA Generic Design Assessment Process, PSA2017, Pittsburgh, PA, September 24-27, 2017.*



## 7. Additional Risk-informed Activities

HITACHI



### Risk-informed improvements recommended from FPSA

1. Systematic identification of risk-reduction options by
  - PSA result / sensitivity analyses / assumptions / uncertainties
  - Involvement of designers/operators
2. Examination of risk-reduction options
  - Reasonably practical or grossly disproportionate?
  - Phase of implementation?
3. Disposition: either of
  - No further options reasonably practicable
  - Implemented into design
  - To be assessed in later design phase

e.g., use closed duct for risk-significant raceway, de-power specific valve

### Use of FPSA to support various decision making

e.g., change in layout (tray, panel), ignition source quantity

More information found in:

*Y. Ishiwatari, et al., "Risk-Informed Design for UK ABWR Project", Int. Conf. on Topical Issues in Nuclear Installation Safety, IAEA CN-251, Vienna, Austria, June 2017.*

## 8. Conclusions

- FPSA of UK ABWR generic design encountered challenges unique to applying the existing guidance.
- Challenges were overcome by **initial simplified approaches** followed by **model refinements** as well as **risk-informed improvements**.
- It was possible to demonstrate that the internal fire risk of UK ABWR was reduced **as low as reasonably practicable at the generic design phase**.
- Adequacy of FPSA was examined by Peer Review.
- It is intended to demonstrate further risk reduction in the later project phase based on more detailed design / operational information and continued risk-informed improvements.

**END Thank you for your attention.**

---

### Acknowledgements

*The authors would like to acknowledge the contributions from the industry experts to the UK ABWR FPSA, including D. Henneke of GE-Hitachi, R. Rogan of EPM, M. Merriman of ARS, J. Grobbelaar of PRIME PRA and E. Jorgenson of ENERCON, as well as the designers/practitioners in Hitachi-GE and Jacobsen, and the independent peer review team led by P. Knoespel of ATKINS.*